FM Approvals

Valves | Water Control Valves (OS&Y and NRS Gate Valves) | Gate Valves, Inside Screw

Model 1112

Product Description

Resilient Seated Gate Valves. 3 through 12 inch NPS. Available with the following end connections and rated working pressure:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
1112	3, 4, 5, 6, 8, 10, 12	(80, 100, 125, 150, 200, 250, 300)	362	(2495)	MJ

FM Approvals

Details

Category	Gate Valves, Inside Screw
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	China

Company

- **Shandong Lede Machinery Co. Ltd.**
- No. 3998 West Weihuan N Rd, Weicheng Dist, Weifang City, Shandong 261057, China
- **http://wflede.com**