FM Approvals

Valves | Water Control Valves (OS&Y and NRS Gate Valves) | Gate Valves, Outside Screw and Yoke

Model 1211

Product Description

Resilient Seated Gate Valves. 3 through 12 inch NPS. Available with the following end connections and rated working pressure:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
1211	3, 4, 5, 6, 8, 10, 12	(80, 100, 125, 150, 200, 250, 300)	362	(2495)	Groove x Groove (AWWA)

Details

Category	Gate Valves, Outside Screw and Yoke
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved

Company

- **Shandong Lede Machinery Co. Ltd.**
- No. 3998 West Weihuan N Rd, Weicheng Dist, Weifang City, Shandong 261057, China
- **http://wflede.com**

Approvals

Listing Country	China