FM Approvals

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Pipe Fittings, Welded Pipe Outlets

Models J02R , J01

Product Description

Model No	Description	Nominal Pipe Size, in	Outlet Connection, in	Rated Working Pressure		Remarks
				psi	(kPa)	
J02R	Welded Outlet Fitting (Grooved Outlet)	1 1/2, 2, 2 1/2, 3, 4, 5, 6, 8	1 1/4 (32)	300	(2065)	a, c, d, f
J02R	Welded Outlet Fitting (Grooved Outlet)	2, 2 1/2, 3, 4, 5, 6, 8	1 1/2 (40)	300	(2065)	a, c, d, f
J02R	Welded Outlet Fitting (Grooved Outlet)	2 1/2, 3, 4, 5, 6, 8	2 (50)	300	(2065)	a, c, d, f
J02R	Welded Outlet Fitting (Grooved Outlet)	3, 4, 5, 6, 8	2 1/2 (65)	300	(2065)	a, c, d, f
J02R	Welded Outlet Fitting (Grooved Outlet)	3, 4, 5, 6, 8	76.1 mm	300	(2065)	a, c, d, f
J02R	Welded Outlet Fitting (Grooved Outlet)	4, 5, 6, 8	3 (80)	300	(2065)	a, c, d, f
J02R	Welded Outlet Fitting (Grooved Outlet)	5, 6, 8	4 (100)	300	(2065)	a, c, d, f
J01	Welded Outlet Fitting (Threaded Outlet)	1 1/4, 1 1/2, 2, 2 1/2, 3, 4, 5, 6, 8	1/2 (15)	300	(2065)	a, b, d, e

FM Approvals

Model No	Description	Nominal Pipe Size, in	Outlet Connection, in	Rated Working Pressure		Remarks
				psi	(kPa)	
J01	Welded Outlet Fitting (Threaded Outlet)	1 1/4, 1 1/2, 2, 2 1/2, 3, 4, 5, 6, 8	3/4 (20)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	1 1/4, 1 1/2, 2, 2 1/2, 3, 4, 5, 6, 8	1 (25)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	1 1/2, 2, 2 1/2, 3, 4, 5, 6, 8	1 1/4 (32)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	2, 2 1/2, 3, 4, 5, 6, 8	1 1/2 (40)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	2 1/2, 3, 4, 5, 6, 8	2 (50)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	3, 4, 5, 6, 8	2 1/2 (65)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	4, 5, 6, 8	3 (80)	300	(2065)	a, b, d, e
J01	Welded Outlet Fitting (Threaded Outlet)	5, 6, 8	4 (100)	300	(2065)	a, b, d, e

Remarks:

a. Outlet connection achieved by welding fitting to pipe, requires precutting of hole in pipe.

b. For use with NPT Threaded End Connections according to ANSI B1.20.1 specifications

c. For use with Rolled Groove End Connections

d. Manufactured out of ASTM A795 Schedule 10 sprinkler pipe

e. For use with BSPT Threaded End Connections according to ISO 7-1 specifications

f. Manufactured out of ASTM A 53 Schedule 40 sprinkler pipe with cut groove end connections.

FM Approvals

Details

Category	Pipe Fittings, Welded Pipe Outlets
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	China

Company

- **Shandong Lede Machinery Co. Ltd.**
- No. 3998 West Weihuan N Rd, Weicheng Dist, Weifang City, Shandong 261057, China
- **http://wflede.com**