ONLINE CERTIFICATIONS DIRECTORY

HLCV.EX27282
Strainers, Pipeline

Page Bottom

Strainers, Pipeline

See General Information for Strainers, Pipeline

SHANDONG LEDE MACHINERY CO LTD EX27282
No 3998
West Waihuan N Rd
Weicheng District
Weifang, Shandong 261057 CHINA

Strainers, Y type, Model(s) Model 6101, in sizes 2, 2.5, 3, 4, 5, 6 and 8 with rated pressure of 300 psi utilize an ASME/ANSI B16.1 Class 125 Flange. Loss of head will approximate 2.96 psi (20.43 kPa) for the 2 in. size at 156.9 GPM (594 LPM), 2.91 psi (20.08 kPa) for the 2.5 in. size at 223.8 GPM (847 LPM), 2.76 psi (19.01 kPa) for the 3 in. size at 345.6 GPM (1308 LPM), 2.28 psi (15.69 kPa) for the 4 in. size at 595.2 GPM (2253 LPM), 1.81 psi (12.45 kPa) for the 5 in. size at 935.3 GPM (3541 LPM), 1.70 psi (11.74 kPa) for the 6 in. size at 1350.7 GPM (5113 LPM), 2.37 psi (16.32 kPa) for the 8 in. size at 2338.9 GPM (8854 LPM).

Strainers, Y type, Model(s) Model 6102, in sizes 2, 2.5(76.1mm), 3, 4, 5, 5(139.7mm), 6, 6(165.1mm) and 8 with rated pressure of 362 psi utilize an AWWA C606 Groove. Loss of head will approximate 2.96 psi (20.43 kPa) for the 2 in. size at 156.9 GPM (594 LPM), 2.91 psi (20.08 kPa) for the 2.5 in. size at 223.8 GPM (847 LPM), 2.76 psi (19.01 kPa) for the 3 in. size at 345.6 GPM (1308 LPM), 2.28 psi (15.69 kPa) for the 4 in. size at 595.2 GPM (2253 LPM), 1.81 psi (12.45 kPa) for the 5 in. size at 935.3 GPM (3541 LPM), 1.70 psi (11.74 kPa) for the 6 in. size at 1350.7 GPM (5113 LPM), 2.37 psi (16.32 kPa) for the 8 in. size at 2338.9 GPM (8854 LPM)

Last Updated on 2016-12-05

Questions? Print this page Terms of Use Page Top

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".