ONLINE CERTIFICATIONS DIRECTORY

VIZM7.EX15228
Fittings, Rubber Gasketed Certified for Canada

Page Bottom

Fittings, Rubber Gasketed Certified for Canada

See General Information for Fittings, Rubber Gasketed Certified for Canada

WEIFANG LEDE MACHINERY CO LTD EX15228
NO 3998
WEST WAIHUAN N RD
WEICHENG DISTRICT
WEIFANG, SHANDONG 261057 CHINA

Coupling

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (kPa)
XGQT1	Cut	40	1, 1-1/4, 1-1/2, 4, 6, 8	1550
XGQT1	Rolled	40	2, 2-1/2, 3	1550
XGQT1	Rolled	GB/T3091	2-1/2, 5	1550
XGQT1	Rolled	GB/T3092	6	1550
XGQT1-M1	Cut	40	4, 6, 8	3450
XGQT1-M1	Cut	GB/T8163	5	3450

Flexible coupling

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (kPa)
XGQT2	Rolled	40	2, 2-1/2, 3	1550
XGQT2	Cut	40	4	1550
XGQT2	Rolled	GB/T3091	2-1/2	1550

Side outlet

Model	Outlet Type	Outlet Pipe	Main Run, in.	Outlet Size, in.	Rated Pressure, (kPa)
XGQT04	Threaded	40	1-1/4	1/2	1550
XGQT04	Threaded	40	1-1/2	1/2	1550
XGQT04	Threaded	40	2	1/2	1550
XGQT04	Threaded	40	2-1/2	1/2	1550
XGQT04	Threaded	40	3	1, 1-1/4, 1-1/2	1550
XGQT04	Threaded	40	4	1, 1-1/4, 1-1/2, 2	1550
XGQT04	Threaded	GB/T3091	139.7 mm	1, 1-1/4, 1-1/2, 2	1550
XGQT04	Threaded	GB/T3092	165 mm	1, 1-1/4, 1-1/2, 2	1550

Model XGQT04 in the 1/2, 3/4, and 1 in. nominal outlet size is intended for direct connection to sprinklers.

Model XGQT04 in the 1 in. and larger nominal outlet sizes are intended for connection to system piping.

40 refers to Schedule 40 steel pipe in accordance with NFPA 13.

GB/T3091 refers to steel pipe manufactured in accordance with GB/T3091.

GB/T3092 refers to steel pipe manufactured in accordance with GB/T3092.

GB/T8163 refers to steel pipe manufactured in accordance with GB/T8163.

Trademark and/or Tradename: LENE

Last Updated on 2010-08-24

Questions? Print this page Notice of Disclaimer Page Top

Copyright © 2010 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

