CERTIFICATE OF COMPLIANCE

Certificate Number 20150709-EX26457
Report Reference EX26457-20150408
Issue Date 2015-JULY-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

PRODUCT SUBMITTED:

UL

Model	Size, in.	Body Type	Pressure Rating, psig	Indicator Post	Supervisory Switch*
XD381X	2,2.5,3,4,5, 5(139.7mm)6,6(165.1mm)	Groove	362	-	I, O
	8		232		I, O
XD371X	2,2.5,3,4,5,6	Wafer	362		I, O
	8,10,12		232		I, O

CUL

*Model	Size, in.	Body Type	Pressure Rating, psig,	Indicator Post	Supervisory Switch*
XD381X	2.5,3,4,5,5(139.7mm),6,6(165.1mm)	Groove	300	-	I, O
	8		232		I, O
XD371X	2,5,3,4,5,6	Wafer	300		I, O
	8,10,12		232		I, O

Note:
For the valve sizes 6 in. and smaller, configured with operator CDT-24, for the valve sizes 8 in. and larger, configured with operator CDT-30.
The shaft material designation is SS431

Steve Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/